

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

October 8, 2009

ORION FITTINGS, INC. ENGINEERING DWIGHT GRAVES P.O. BOX 17-1580 KANSAS CITY KS 66117

Re: Description: FAUCET, LABORATORY

Manufacturer: ORION FITTINGS, INC.

Product Name: PP AND PVDF PURE WATER FAUCETS

Model Number(s): GNF10VB, GNF20VB, GNF30VB AND GNF40VB

Product File No: 20090370

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.20 (6) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in conformance with s. Comm 82.41, Wis. Admin. Code.
- Approval is issued for this product because the design of the product meets the intent of s. Comm 84.20 (6) (a), Wis. Adm. Code that requires faucets to meet ANSI standard A112.18.1. The intent is met since this product is designed and constructed to produce a faucet for it's intended use that is equal to the requirements of the standard.

This approval supersedes the approval issued on August 19, 2004 under product file number 20040442.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040442.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742

Fax: 608-267-9566 E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 09037001.DOC